

	Community Development Permit Center	Procedure:	BLDG-0130
	One Twin Pines Lane, Suite 110 Belmont, CA 94002	Effective Date:	1/15/2016
	Center-Fed Electrical Distribution Panels	Last Revised:	1/15/2016
		Approved by:	
		Mark A. Nolfi Building Official	

Per Section 705.12(D)(7) of the National Electrical Code

The following requirements will be met in the installation of a photovoltaic system:

A center-fed electrical distribution panel is limited to 100% of the bus bar rating of the panel. The sum of the ampere ratings of all overcurrent supply devices cannot exceed 100% of the rating of the panel board. The 120% allowance on end-fed panels is not allowed.